Annual Drinking Water Quality Report 2021 BRWCD-Riverside/North Garland UTAH02070



We're pleased to present to you this year's Annual Drinking Water Quality Report. This report is designed to inform you about the quality of the water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water sources have been determined to be from groundwater sources. Our water source is Sleepy Hollow Spring and the Lower Beaver Spring.

The Drinking Water Source Protection Plan for Bear River Water Conservancy District is available for your review. It contains information about source protection zones, potential contamination sources and management strategies to protect our drinking water. Our sources have been determined to have a low level of susceptibility from potential contamination from sources such as septic tanks, roads, residential areas, industrial areas, etc. We have also developed management strategies to further protect our sources from contamination. Please contact us if you have questions or concerns about our source protection plan.

There are many connections to our water distribution system. When connections are properly installed and maintained, the concerns are very minimal. However, unapproved and improper piping changes or connections can adversely affect not only the availability, but also the quality of the water. A cross connection may let polluted water or even chemicals mingle into the water supply system when not properly protected. This not only compromises the water quality but can also affect your health. So, what can you do? Do not make or allow improper connections at your homes. Even that unprotected garden hose lying in the puddle next to the driveway is a cross connection. The unprotected lawn sprinkler system after you have fertilized or sprayed is also a cross connection. When the cross connection is allowed to exist at your home, it will affect you and your family first. If you'd like to learn more about helping to protect the quality of our water, call us for further information about ways you can help.

This report shows our water quality and what it means to you, our customer. If you have any questions about this report or concerning your water utility, please contact the BRWCD General Manager, Carl Mackley, at 435-723-7034. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are usually held on the fourth Wednesday of each month at 7:00 p.m. in the BRWCD District Office Conference Room at 102 West Forest Street, Brigham City, Utah. Check the schedule on our website.

Bear River Water Conservancy District routinely monitors for constituents in our drinking water in accordance with the Federal and Utah State laws. The following table shows the results of our monitoring for the period of January 1, 2021 to December 31, 2021.

We're proud to report that your drinking water met state and federal requirements during 2021.



## • IN THE FOLLOWING TABLE YOU WILL FIND MANY TERMS AND ABBREVIATIONS YOU MIGHT NOT BE FAMILIAR WITH. TO HELP YOU BETTER UNDERSTAND THESE TERMS WE'VE PROVIDED THE FOLLOWING DEFINITIONS:

Non-Detects (ND) - laboratory analysis indicates that the constituent is not present.	ND/Low - High - For water systems that have multiple sources of water, the Utah Division of Drinking Water has given water systems the option of listing the test results of the constituents in one table, instead of multiple tables. To accomplish this, the lowest and highest values detected in the multiple sources are recorded in the same space in the report table.
Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.	Parts per billion (ppb) or Micrograms per liter (ug/l) - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.
Parts per trillion (ppt) or Nanograms per liter (nanograms/I) - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.	Parts per quadrillion (ppq) or Picograms per liter (picograms/l) - one part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.
Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.	Millirems per year (mrem/yr) - measure of radiation absorbed by the body.
Nephelometric Turbidity Unit (NTU) - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.	Action Level (AL) - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.	Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Date- Because of required sampling time frames i.e. yearly, 3 years, 4 years and 6 years, sampling dates may seem outdated.	Waivers (W) Because some chemicals are not used or stored in areas around drinking water sources, some water systems have been given waivers that exempt them from having to take certain chemical samples, these waivers are also tied to Drinking Water Source Protection Plans.



	TEST RESULTS							
	Contaminant	Year Sampled	Level Detected ND/Low-High	Unit Measurement	MCLG	MCL	Violation Y/N	Likely Source of Contamination
Microbiological Contaminants								
Total Colif	orm Bacteria	2021	ND		NA	0	Ν	Presence of coliform bacteria in 5% of monthly samples
Fecal coliform and <i>E.coli</i>		2021	ND	N/A	0	If a routine sample and repeat sample are total coliform positive, and one is also fecal coliform or <i>E.</i> <i>coli</i> positive	Ν	Human and animal fecal waste
Inorganic Contaminants								
Arsenic		2019	3	ppb	0	10	Ν	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Barium		2019	1	ppm	2	2	Ν	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Flouride		2019	1	ppm	4	4	Ν	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate		2021	1400-4800	ppm	10000	10000	Ν	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Selenium		2019	1	ppb	50	50	Ν	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines.
Sodium		2019	68	ppm	500	None set by EPA	Ν	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills.
Sulfate		2019	33	ppm	1000	1000	Ν	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills, runoff from cropland
TDS (Total	Dissolved Solids)	2019	470	ppm	2000	2000	Ν	Erosion of natural deposits
Lead and Copper								
Copper	a. 90% results	2020	a. 53	ppb	1300	AL=1300	Ν	Corrosion of household plumbing systems, erosion of natural deposits; leaching from wood preservatives
	b. # of sites that exceed the AL		b. 0					
Lead	a. 90% results	2020	a. 3.1	ppb	0	AL=15	Ν	Corrosion of household plumbing systems; erosion of natural deposits
	b. # of sites that exceed the AL		b. 0					



	SYNTHETIC ORGANIC CONTAMINANTS INCLUDING PESTICIDES AND HERBICIDES							
Acylamide	2019	W	N/A	0	Π	TT	Added to water during sewage/wastewater treatment	
Dibromochloro-propane	2019	W	ppt	0	200	Ν	Runoff/leaching from soil fumigant used on soybeans, cotton, pineapples and orchards	
Dioxin (2,3,7,8-TCDD)	2019	W	ppb	0	30	Ν	Emissions from waste incineration and other combustion; discharge from chemical factories	
Diquat	2019	W	ppb	20	20	Ν	Runoff from herbicide use	
Endothall	2019	W	ppb	100	100	Ν	Runoff from herbicide use	
Epichlorohydrin	2019	W	N/A	0	Π	π	Discharge from industrial chemical factories; an impurity of some water treatment chemicals	
Ethylenedibromide	2019	W	ppt	0	50	Ν	Discharge from petroleum refineries	
Glyphosate	2019	W	ppb	700	700	N	Runoff from herbicide use	
VOLATILE ORGANIC CONTAMINANTS								
TTHM [Total trihalomethanes]	2021	4.5	ppb	0	100	N	By-product of drinking water disinfection	
				Regu	ulated Contaminants			
Total Trihalomethanes	2019	2	ppb	0	80	N	By-product of drinking water disinfection	
Haloacetic Acids	2019	2	ppb	0	60	N	By-product of drinking water disinfection	
Chlorine	2017	0.2	ppm	4	4	N	By-product of drinking water disinfection	
RADIOACTIVE CONTAMINANTS								
Alpha Emitters	2020	7	pCi/1	0	15	N	Erosion of natural deposits	
Combined Radium 226/228	2020	0.27	pCi/l	0	5	N	Erosion of natural deposits	
Beta/photon emitters	2020	16	pCi/1	0	50	N	Decay of natural deposits	
Turbidity								
Turbidity	2019	-1	NTU	0	0.3	N	Soil Runoff	

EPA requires monitoring of over 80 drinking water contaminants. Those contaminants listed in the table above are the only contaminants detected in your drinking water.



Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline: (800) 426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from:

Safe Drinking Water Hotline: (800) 426-4791

